

(a) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2018-06-20	TECHNICIAN Darren Mann		JOB/O 8601	RDER #	REFERENCE TEXT
FIRST NAME Changho		LAST NAME Kang	7		
BILLING ADDRESS		10	7.	SERVICE ADDRESS	
3161 WEST 4TH AVE VANCOUVER, V6K1R6 BRITISH COLUMBIA, CANADA				#409 - 3161 WEST 4TH AVE, B VANCOUVER, V6K1R6 BRITISH COLUMBIA, CANADA	
PHONE 604.730.8324				EMAIL hedgehogandfox@yahoo.ca	

REASON FOR TODAY'S CALL: Toilet running.

## DESCRIPTION OF WORK PERFORMED:

The ensuite toilet fillvalve was replaced a month prior to my visit. The fillvalve used was of poor quality and was set too high. I tried to reset the height o the fillvalve but it still failed to operate correctly. I replaced the fillvalve and supply line and tested.

<b>QTY</b> .	CODE		UNIT PRICE	PRICE	
1	/	Replace toilet FillValve -	\$159.00	\$159.00	
1	6	Nice Guy Discount :)		-\$20.00	-\$20.00
Gwe us Feedbac			ANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$139.00
Please visit our feedback page at: <u>www.yaletownplumbing.com/feedback</u> [1] Fill in the required details from your invoice and tell us how we did. <u>Thank Youl</u>			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$6.95
		Is from your	WARRANTY ON CUSTOMER SUPPLIED MATERIALS.	TOTAL:	\$145.95
		MAT SET RES TER	IE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND ERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, TLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES ULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. <u>MS</u> : NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK RGES. E. & O. E.		
			2018-06-20		
			CUSTOMER SIGNATURE DATE		