

HST #837181627

DATE 2018-08-14	TECHNICIAN Darren Mann		JOB/ORDER # 8756	REFERENCE TEXT Client reference	
FIRST NAME Susan		LAST NAME Cahill			
BILLING ADDRESS COMPANY / BILLING NAME 210 - 1477 WEST 15TH AVE VANCOUVER, V6H 1S4 BRITISH COLUMBIA, CANADA			SERVICE ADDRES 210 - 1477 WEST 1 VANCOUVER, V6H BRITISH COLUMB	5TH AVE H 1S4	
PHONE 604.724.2805			EMAIL mssusancahill@gm	nail.com	

## REASON FOR TODAY'S CALL:

Very low to zero water pressure in my kitchen faucet.

## **DESCRIPTION OF WORK PERFORMED:**

The shut off valves under the sink(connected to the faucet) were breaking down internally. I repaired these valves by replacing the washers, stems, packing, packing nuts, and handles. I then flushed debris out of the lines as well as the spray hose coupling(Grohe) and tested. Pressure is back to normal.

QTY.	CODE	DESCRIPTION			PRICE
1		Repair 1/2" x 3/8" Angle or	\$139.00	\$139.00	
1	//	Repair 1/2" x 3/8" Angle or Straight Stop - ADD-ON			\$25.00
Give us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				SUBTOTAL:	\$164.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.  INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS ACKNOWLEDGEMENT IS HEREBY.		\$8.20
		s from your			\$172.20

Thank You!

invoice and tell us how we did.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES, E. & O. E.

2018-08-14

CUSTOMER SIGNATURE

DATE