

(B) @SimplyPlumbing | YaletownPlumbing

HST #837181627

DATE 2018-11-13	TECHNICIAN Darren Mann		JOB/ORDER # 8984	REFERENCE TEXT Client reference	-
FIRST NAME Easyrent		LAST NAME Admin			
BILLING ADDRESS EASYRENT REAL ESTATE SERVICES LTD. 100 - 1290 HOMER ST VANCOUVER, V6B2Y5 BRITISH COLUMBIA, CANADA			SERVICE ADDRES  2804 - 888 HOMER HANY: 1.416.910.0 KEY WITH CONCI VANCOUVER, BRITISH COLUME	R ST 1790 ERGE.	
PHONE 604.662.3279		EMAIL info@easyrent.ca			

## REASON FOR TODAY'S CALL:

Toilet not refilling after flushed.

## DESCRIPTION OF WORK PERFORMED:

The fillvalve was not properly refilling the tank after a flush. I installed a new fillvalve and supply line and tested.

## TECHNICIAN RECOMMENDATIONS:

A notice went out to owners in this building recommending replacement of the laundry hoses. I believe the hoses within this unit are the original and should be replaced with braided stainless type hoses.

QTY.	CODE	DESCRIPTION		PRICE
1		Discount Labour		\$99.00
1	2121352	B1-16DL 3/8X20 SPEEDI+ WC CONN		\$11.00
1	9520164	PRO45B ANTI-SYPH FILL VLV UQ	\$35.00	\$35.00
0	we us Feedback warranty: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY		SUBTOTAL:	\$145.00
	sit our feedbac	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.25
www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did.			TOTAL:	\$152.25
		INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY		

Thank You!

MADE THAT OFFICION AND ADDITION AND CATIONAL TOP AND THAT CHAPGES AND
MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND
MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,
SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGE:
RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK
CHARGES, E. & O. E.
2018-11-13

CUSTOMER SIGNATURE