

Phone: (604) 727-4484 yaletownplumbing.com





HST #837181627

DATE 2012-08-23	TECHNICIAN Evan Brandle		JOB/ORDER # 580	REFERENCE TEXT
FIRST NAME Jinn-Erik		LAST NAME Tveita		
BILLING ADDRESS			SERVICE ADDRESS	
#604 - 1238 BURRAR VANCOUVER, V6E3E BRITISH COLUMBIA,	1		#604 - 1238 BURRAR VANCOUVER, V6E3E BRITISH COLUMBIA,	1
PHONE 604.616.2891			EMAIL jinnerikst@gmail.com	

REASON FOR TODAY'S CALL:

Toilet had a flood and is inoperable. Would like to get it repaired. Prior to the flood it had issues filling, and then as a result of the unit owner's sketchy repair, would be constantly filling up. Also, second toilet in unit is having flow issues. Finally, we would like a plumbing audit, not too sure what kind of maintenance this unit has had. (building is 8 years old)

DESCRIPTION OF WORK PERFORMED:

-replaced fill valve in toilet and replaced water supply hose to toilet

TECHNICIAN RECOMMENDATIONS:

Cause of flood was the defective fill valve in the toilet

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	9520164	PRO45B ANTI-SYPH FILL VLV UQ		\$25.00
1	IIF	Labour		\$99.00
1	2121352	B1-20DL 3/8X20 SPEEDI+ WC CONN		\$8.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				\$132.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did.		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	HST (12%):	\$15.84
			TOTAL:	\$147.84
		INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY		

Thank You!

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN. SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK

CHARGES. E. & O. E.

2012-08-23