



YALETOWN PLUMBING & HEATING LTD
 1503-1255 Seymour St. Vancouver, BC V6B 0H1
 Phone: (604) 727-4484 yaletownplumbing.com



INVOICE
3588

HST #837181627

DATE 2012-10-17	TECHNICIAN Kristian Evans	JOB/ORDER # 767	REFERENCE TEXT Client reference
FIRST NAME Fred		LAST NAME Vertone	
BILLING ADDRESS COMPANY / BILLING NAME 1551 VINSON CREEK ROAD WEST VANCOUVER, BRITISH COLUMBIA, CANADA		SERVICE ADDRESS #801 - 1740 ESQUIMALT VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.926.3806		EMAIL fred.vertone@shaw.ca	

REASON FOR TODAY'S CALL:
 -inspect source of sewer smell.

DESCRIPTION OF WORK PERFORMED:
 Inspected tenants laundry drain. Confirmed a ptrap is installed. Checked dryer vent, and strange odour is present. Checked roof top, dryer vent smell is not on roof vent. Found water sitting in the vent stack and strong septic odour present which is normal for the top of a vent stack.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1.5		Discount Labour 75	\$75.00	\$112.50

Give us Feedback

Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.

Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$112.50
HST (12%):	\$13.50
TOTAL:	\$126.00

_____ 2012-10-17
 CUSTOMER SIGNATURE DATE