



DATE 2012-11-06	TECHNICIAN Kristian Evans	JOB/ORDER # 845	REFERENCE TEXT Client reference
FIRST NAME Vira		LAST NAME Prykhodko	
BILLING ADDRESS DODWELL STRATA MANAGEMENT LTD 1166 ALBERNI ST SUITE#1701 VANCOUVER, V6E3Z3 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 108 WEST CORDOVA ST VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.699.5261		EMAIL virap@dodwell.ca	

REASON FOR TODAY'S CALL:

-Two suites reported no heating: 3007 and 2502. -1601 reported weird sound near the heater: constant hissing sound coming from the base heater by the exhaust side in the bedroom. The intake side is in the kitchen.

DESCRIPTION OF WORK PERFORMED:

-made adjustment to zone valves in units 3007 & 2502. if these valves continue to be an issue they will need to be replaced. -the shut off valve in unit 1601 wasn't fully open, i opened valve fully.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1.5		Labour	\$99.00	\$148.50
SUBTOTAL:				\$148.50
HST (12%):				\$17.82
TOTAL:				\$166.32

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

_____ 2012-11-06

 CUSTOMER SIGNATURE DATE