





UNIT PRICE

HST #837181627

DATE 2012-12-12	TECHNICIAN darren mann		JOB/ORDER # 1005	REFERENCE TEXT WO#4355	
FIRST NAME Andrea		LAST NAME Ferina		·	
BILLING ADDRESS ADVENT REAL ESTA #204 - 1168 HAMILTO VANCOUVER, V6B2S BRITISH COLUMBIA,	DN ST S2	79	SERVICE ADDRESS 6211 MARUERITE S VANCOUVER, BRITISH COLUMBIA	ST	
PHONE 604.736.6478			EMAIL andrea@adventvand	ouver.com	

## REASON FOR TODAY'S CALL:

-pinhole leak in water piping

## **DESCRIPTION OF WORK PERFORMED:**

-replaced leaking portion of Poly-B pipe in the ceiling across from the washer & dryer in the basement.

## TECHNICIAN RECOMMENDATIONS:

CODE

-the air outlet on the AIR SEPARATOR next to the boiler has a small amount of water leaking out, there is a bucket underneath it collecting this drip for now but the AIR SEPARATOR may need replacing. i suggest having a heating specialist take a look at this and the rest of the system to make sure it is running at full optimization.

**DESCRIPTION** 

1	1 Discount Labour 89			\$89.00
1	Materials Used		\$10.00	\$10.00
WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			SUBTOTAL:	\$99.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.	HST (12%):	\$11.88
			TOTAL:	\$110.88

CUSTOMER SIGNATURE

Thank You!

invoice and tell us how we did.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2012-12-12

DATE