

YALETOWN PLUMBING SERVICES LTD
1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2013-06-13	TECHNICIAN Kristian Evans		JOB/ORDER # 1771	REFERENCE TEXT Client reference	
FIRST NAME Alan		LAST NAME Nixon			
BILLING ADDRESS DOMINIONGRAND REALTY 2000 - 1500 WEST GEORGIA ST VANCOUVER, V6G2Z6 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS #1706 - 833 SEYMOUR ST BUZ#1141 JOHN 604.725.4335 VANCOUVER, BRITISH COLUMBIA, CANADA			
PHONE 604.644.7756		EMAIL ajnixon@shaw.ca			

REASON FOR TODAY'S CALL:

DESCRIPTION OF WORK PERFORMED:

-the toilet fill-valve was squealing while filling the tank and the float mechanism was sticky and would stay open on some flushes. -Replaced fill-valve,flapper, and

TECHNICIAN RECOMMENDATIONS:

-overflowing of the toilet will happen when you have a toilet blockage and a running toilet.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	\mathbb{H}_{2}	Replace Toilet Fill-Valve, Flapper, Supply - Standard		\$169.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				\$169.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did.		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$8.45
		s from your	TOTAL:	\$177.45
		INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY		

<u> Thank You!</u>

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2013-06-13 CUSTOMER SIGNATURE DATE

^{-&}quot;toilet overflowing. Also a loud squeaking noise."