

YALETOWN PLUMBING SERVICES LTD 1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2013-08-19	TECHNICIAN Kristian Evans		JOB/ORDER # 2053		REFERENCE TEXT
FIRST NAME Vira		LAST NAME Prykhodko			
BILLING ADDRESS PETERSON RESIDENTIAL 1166 ALBERNI ST SUITE#170' VANCOUVER, V6E3Z3 BRITISH COLUMBIA, CANADA				#2501/2601 - 108 WEST CORD CARETAKER JOSEPHINE 778.991.2397 CONCIERGE 778.288.7225 VANCOUVER, V6E3Z3 BRITISH COLUMBIA, CANADA	
PHONE 604.699.5261				EMAIL virap@dodwell.ca	

REASON FOR TODAY'S CALL:

DESCRIPTION OF WORK PERFORMED:

Inspected ceiling above shower in 2501. There was clearly water damage present. The ceiling however was dry when I was inspecting it. I cut open the drywall. People in 2601 were using their shower and could hear water running through the drain. No signs of water leaking, nor was there any moisture present in the ceiling space. I believe this damage could be from the previous leak as there was no leak present at this time, nor was there any moisture.

QTY. CODE	DESCRIPTION			
1 Labour		\$99.00	\$99.00	
Gwe us Feedback	WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$99.00	
Please visit our feedback page at:	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$4.95	
www.yaletownplumbing.com/feedback [1] Fill in the required details from your	WARRANTY ON CUSTOMER SUPPLIED MATERIALS. INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY	TOTAL:	\$103.95	
Thank You!	MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.			

CUSTOMER SIGNATURE

DATE

⁻leaking reported in ceiling of #2501. NOTE: repairs to a leaking shower in #2601 have recently been made by another plumbing company