

Phone: 604.727.4484 yaletownplumbing.com



2013-10-25



HST #837181627

DATE 2013-10-25	TECHNICIAN Kristian Evans Christopher Ryz Darren Mann		JOB/C 2397	PRDER #	REFERENCE TEXT Client reference	
FIRST NAME Neil		LAST NAME Allen				
BILLING ADDRESS COMPANY / BILLING NAME 1996 WEST 42ND AVE VANCOUVER, V6M2B1 BRITISH COLUMBIA, CANADA				SERVICE ADDRESS  1996 W 42ND AVE CLARA(DAUGHTER): 778.60 VANCOUVER, V6M2B1 BRITISH COLUMBIA, CANA		
PHONE 778.241.4111				EMAIL neilallen@shaw.ca		

## REASON FOR TODAY'S CALL:

"the trap (ubend) for the bath is leaking. we have access to that end of the bath."

## DESCRIPTION OF WORK PERFORMED:

OCT25---replaced ptrap, and waste and over flow kit. OCT29---tested tub and found small drip coming from the drain connection between new piping and existing. NOV 9th- removed cremco adaptor and found small piece of debris stuck on inner wall of clamp. I removed this debris, re-connected the ptrap and tightened the cremco clamp. Filled tub 3 times and drained to test, no signs of leaking present. I placed a small Tupperware container under the tub drain and cremco connection and inserted a small water detector alarm to alert the homeowner of potential leaking before it becomes a bigger problem.

## TECHNICIAN RECOMMENDATIONS:

although the tub has an inner liner that was very difficult to work with, i have subtracted hours from the total to help make the cost more reasonable. (actual hours spent on job 6)

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
3.5		Labour	\$99.00	\$346.50
1		Materials Used	\$80.00	\$80.00
<i>Q</i>	(1	WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$426.50
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did.  Thank Youl		k page at:  LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF  MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$21.33
			TOTAL:	\$447.83
		MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT, YALLETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED BUTTER DETERMINATION LEAD DIDES SIXTURES CHEAN OUTS AND ANY OTHER DAMAGES.		

CUSTOMER SIGNATURE