

YALETOWN PLUMBING SERVICES LTD
1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2014-01-09	TECHNICIAN Darren Mann		JOB/O 2792	RDER #	REFERENCE TEXT
FIRST NAME Jewel		LAST NAME Staite	97		
BILLING ADDRESS			///	SERVICE ADDRESS	
1801 198 AQUARIUS MEWS VANCOUVER, V6Z2Y4 BRITISH COLUMBIA, CANADA				1801 - 198 AQUARIUS MEWS VANCOUVER, V6Z2Y4 UNKNOWN, CANADA	
PHONE 604.505.1513				EMAIL jbstaite@gmail.com	

## REASON FOR TODAY'S CALL:

"I think it's the garburator or sink that's completely clogged. Tried drano to no avail. The water won't go down the drain at all at this point." buz#3601

## **DESCRIPTION OF WORK PERFORMED:**

-used the PowerSpin drain snake to clear the kitchen sink blockage. -i noticed the water pressure in the kitchen faucet was quite low. the low pressure could potentially contribute to future drain blockages as it is hard to get sufficient water from the faucet to wash away food debris created by the garburator. i noticed that the shut off valves under the kitchen sink are not working. this most likely is caused by the washers within the valves wearing out and falling apart. this could also be the cause for the low water pressure as pieces of the rubber washer are most probably caught in various areas within the faucet itself.

## TECHNICIAN RECOMMENDATIONS:

-i recommend repairing the hot and cold shut off valves under the kitchen sink as they may be needed in the future. -i also recommend finding out where the main water shut off valves are located within the apartment. -the kitchen faucet should also be replaced.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	II R	Clean drain using PowerSpin / Kitchen sink	\$149.00	\$149.00
<i>Q.</i>	SUBTOTAL:	\$149.00		
Gwe us Feedback  Please visit our feedback page at:  www.yaletownplumbing.com/feedback  [1]  Fill in the required details from your		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.45
			TOTAL:	\$156.45
	tell us how v	MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLE RESPONSIBLE FOR BROKEN, AND AND AND AND AND AN		

CUSTOMER SIGNATURE

2014-01-09

DATE