

YALETOWN PLUMBING SERVICES LTD
1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2014-01-31	TECHNICIAN Christopher Ryz		JOB/O 2908	RDER#	REFERENCE TEXT
FIRST NAME Wendy		LAST NAME He	97		
BILLING ADDRESS  1203 - 989 NELSON ST BUZ#1 VANCOUVER, BRITISH COLUMBIA, CANADA		2	4	SERVICE ADDRESS  1203 - 989 NELSON ST BUZ: VANCOUVER, BRITISH COLUMBIA, CANAL	
PHONE 778.869.6328				EMAIL wendyhe0404@gmail.com	

## REASON FOR TODAY'S CALL:

-leaking under 3 sinks

## **DESCRIPTION OF WORK PERFORMED:**

-Garb was not working due to it being jammed. Showed the tenant how to use the garb key and reset button. - master bathroom shower hose is no good, thoug a wager would work but leaking from another area .. Wendy will get a new hose - en suite toilet was running. Changed the fill valve as well as supply line and gasket for plunger style flapper...also the shut off for the toilet would work then it failed then worked? Installed a retro stop ...

QTY.	CODE		UNIT PRICE	PRICE	
1		Replace Toilet Fill-Valve, Flapper, Supply - Standard			\$169.00
1	11	Retro valve		\$25.00	\$25.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				SUBTOTAL:	\$194.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO		\$9.70
		s from your	WARRANTY ON CUSTOMER SUPPLIED MATERIALS.  REST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY	TOTAL:	\$203.70

RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

Thank You!

invoice and tell us how we did.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E. 2014-01-31 CUSTOMER SIGNATURE DATE

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES