

YALETOWN PLUMBING SERVICES LTD

1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com

🕒 @SimplyPlumbing 🛛 🚹 YaletownPlumbing

HST #837181627

INVOICE

DATE 2014-04-16	TECHNICIAN Darren Mann		JOB/O 3218	RDER #	REFERENCE TEXT Client reference
FIRST NAME Mina		LAST NAME Pooni	7		
BILLING ADDRESS COMPANY / BILLING NAME 2630 WEST 6TH AVE VANCOUVER, V6K1W7 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 2630 WEST 6TH AVE VANCOUVER, V6K1W7 BRITISH COLUMBIA, CANADA	
PHONE 604.730.7126				EMAIL minapooni@hotmail.com	

REASON FOR TODAY'S CALL:

-powder room lav not draining well. -toilet in upstairs master bathroom not flushing well, water at base when flushed.

DESCRIPTION OF WORK PERFORMED:

-removed push top lav drain stopper from lavatory drain in main floor powder room. -replaced the mechanical portion of the fillvalve, as well as the flush valve gasket in the master toilet.

TECHNICIAN RECOMMENDATIONS:

MASTER TOILET: the toilet is missing the Toto floor flange adaptor(just like the toilet on the same floor). Also, the tank bolts are installed upside down making it impossible to remove the tank without lifting the entire toilet to gain access to the tear of the toilet.

QTY .	CODE	DESCRIPTION	UNIT PRICE	PRICE	
1	1 Replace toilet FillValve - standard				
0		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$149.00	
Give us Feedback Please visit our feedback page at: <u>www.yaletownplumbing.com/feedback</u> [1] Fill in the required details from your		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.45	
			TOTAL:	\$156.45	
	d tell us how v	MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,			