

YALETOWN PLUMBING SERVICES LTD 1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2014-06-12	TECHNICIAN Darren Mann		JOB/ORDER # 3455	REFERENCE TEXT Client reference	
FIRST NAME Marv		LAST NAME Bachman			
BILLING ADDRESS COMPANY / BILLING NAME 1483 HOMER VANCOUVER, V6Z3C7 BRITISH COLUMBIA, CANADA		79	SERVICE ADDRESS #2105 - 1483 HOMER VANCOUVER, V6Z3C7 BRITISH COLUMBIA, CANADA		
PHONE 604.893.8344			EMAIL amraceone@aol.com		

REASON FOR TODAY'S CALL:

-replace toilet fill-valve, flapper, supply line.

DESCRIPTION OF WORK PERFORMED:

Replaced the toilet fill-valve, flapper and supply line.

TECHNICIAN RECOMMENDATIONS:

I noticed hairline cracks in the overflow tube but water does not seem to be sealing through. If this overflow tube does require replacement I the future it will be a so racial order from American standard as the toilet is a one piece that does not use the standard overflow assembly.

QTY.	CODE	DESCRIPTION		PRICE
1		Replace Toilet Fill-Valve, Flapper, Supply - Standard	\$169.00	\$169.00
PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			SUBTOTAL:	\$169.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your		GST (5%):	\$8.45	
		s from your	TOTAL:	\$177.45

Thank You!

invoice and tell us how we did.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2014-06-12 CUSTOMER SIGNATURE DATE