

YALETOWN PLUMBING SERVICES LTD 1503-1255 Seymour St. Vancouver, BC V6B 0H1

1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com

(B) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2014-07-31			JOB/ORDER # 2868		REFERENCE TEXT Client reference
FIRST NAME Corrie		LAST NAME Ho	7		
BILLING ADDRESS SUNSTAR REALTY 6 - 3003 KINGSWAY VANCOUVER, V5R5J6 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1202 - 980 COOPERAGE WAY AIDIN(TENANT): 604.729.2877 DARIUS(TENANT): 778.895.127 VANCOUVER, BRITISH COLUMBIA, CANADA	71
PHONE 604.436.1335 ext103				EMAIL corrie@sunstarrealty.ca	

REASON FOR TODAY'S CALL:

-lav faucet running. -take pics and measurements of toilet for toilet replacement quote.

DESCRIPTION OF WORK PERFORMED:

-The cartridge with the guest bathroom lavatory faucet was cracked and not fully stopping the flow of water through the faucet. I replaced this cartridge with new. -I tested the toilet in this same bathroom by flushing rolled up balls of toilet paper 8 times and on the 8th time it did clog, on the 9th flush it flushed fine. The flush is not very strong but the water level in the tank has already been raised on a previous visit and a 6' toilet has been pushed through the toilet with no resistance, there is nothing else that can be done within the tank to make this any better.

TECHNICIAN RECOMMENDATIONS:

If replacement of the toilet is to be made the following measurements will be needed: 1) 29-3/4" to the underside of the countertop above the tank. 2) 12-3/4" from back wall to center of bolt caps.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace Lav Faucet Single Lever Cartridge - Standard	\$149.00	\$149.00
0	a	WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$149.00
Guve us Jeedback page at: <u>www.yaletownplumbing.com/feedback [1]</u> Fill in the required details from your invoice and tell us how we did. <u>Thank Youl</u>		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.45
			TOTAL:	\$156.45
		MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,		
		2014-07-31		
		CUSTOMER SIGNATURE DATE		