

Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2015-02-12	TECHNICIAN Darren Mann		JOB/ORDER # 4432		REFERENCE TEXT
FIRST NAME Corrie		LAST NAME Ho	9/		
BILLING ADDRESS SUNSTAR REALTY 6 - 3003 KINGSWAY VANCOUVER, V5R5J6 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS  207 - 560 NICOLA ST BUZ#13 BEHZAH: 604.363.0135 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.436.1335 ext103				EMAIL corrie@sunstarrealty.ca	

## REASON FOR TODAY'S CALL:

-toilet clogging frequently.

## DESCRIPTION OF WORK PERFORMED:

I used the 6' toilet auger to clear the toilet blockage. The auger did not pull anything out of the toilet, whatever caused the blockage was broken up and flushed through. The FillValve was not functioning properly, on some flushes it wasn't fully filling the tank and bowl after a flush. I replaced the FillValve, flapper, and supply line and tested by flushing rolled up balls of toilet paper.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	//	Replace toilet FillValve - TOTO Universal	\$169.00	\$169.00
Gwe us Feedback  Please visit our feedback page at:  www.yaletownplumbing.com/feedback  Fill in the required details from your invoice and tell us how we did.  Thank You!		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANT	SUBTOTAL:	\$169.00
		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REP		\$8.45
			TOTAL:	\$177.45
		WE did.  MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLIAND ARE CORRECT. YALETOWN PLUMBING SETTLED BLISTED DETERMINATION OF LEAD PIPES SIXTURES.	ETED AND THAT CHARGES AND G IS NOT RESPONSIBLE FOR BROKEN, ELEAN OUTS AND ANY OTHER DAMAGES OR PIPING.	

CUSTOMER SIGNATURE

2015-02-12