

YALETOWN PLUMBING SERVICES LTD
1503-1255 Seymour St. Vancouver, BC V6B 0H1 Phone: 604.727.4484 yaletownplumbing.com





HST #837181627

DATE 2015-04-08	TECHNICIAN Darren Mann		JOB/ORDER # 4632		REFERENCE TEXT Client reference
FIRST NAME Scott		LAST NAME Wardle	7		
BILLING ADDRESS COMPANY / BILLING NAME 950 CAMBIE STREET BUZ#0071 VANCOUVER, V6B 5X5 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1106 - 950 CAMBIE STREET BUZ#0071 BUZZER: 0071 VANCOUVER, V6B 5X5 BRITISH COLUMBIA, CANADA	
PHONE 604.779.8053				EMAIL swardle@gmail.com	

REASON FOR TODAY'S CALL:

Bathroom sink is clogged sink 2 toilets keep running and flushing every 30mins or so. Maybe the problem is bad seal on The plug in side the tank water? Review house for other problems pluming problems.

DESCRIPTION OF WORK PERFORMED:

-I cleared the master lavatory sink drain using the PowerSpin drain snake, and replaced the flappers in both toilets.

QTY.	CODE		UNIT PRICE	PRICE	
1	7	Clean drain using PowerSpin / Lavatory			\$139.00
2	2465350	214L HORNET UNIV FLA	\$8.00	\$16.00	
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				SUBTOTAL:	\$155.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$7.75
			WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		\$162.75

Thank You!

invoice and tell us how we did.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK

CHARGES. E. & O. E.

2015-04-08

CUSTOMER SIGNATURE

DATE