

🕒 @SimplyPlumbing 🛛 🚹 YaletownPlumbing

HST #837181627

DATE 2015-09-10	TECHNICIAN Darren Mann		JOB/ORDER # 5153		REFERENCE TEXT 15-1094	
FIRST NAME Advent		LAST NAME Admin	7			
BILLING ADDRESS ADVENT REAL ESTATE SERVICES LTD. #204 - 1168 HAMILTON ST VANCOUVER, V6B2S2 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 2506 - 610 GRANVILLE ST BELLE: 778.989.4705 VANCOUVER, BRITISH COLUMBIA, CANADA		
PHONE 604.736.6478				EMAIL andrea@adventvancouver.com		

REASON FOR TODAY'S CALL: lavatory faucet running

DESCRIPTION OF WORK PERFORMED:

I replaced the cartridge(K35b) in the lavatory faucet and tested. Faucet in good working order.

TECHNICIAN RECOMMENDATIONS:

The tenant mentioned while onsite that the shower was making a whistling noise. I tested and found that a slight whistling noise could be heard when the temperature of the shower was in a certain position. This whistling is coming from the tub spout and will have to be replaced(I did not have a new spout with me)

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace Lav Faucet Single Lever Cartridge - Standard	\$149.00	\$149.00
0	a	WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$149.00
Give us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!		LABOUR - 1 YEAR ON NEW LINITS 30 DAYS ON REPAIR VOID AFTER 30 DAYS IF	GST (5%):	\$7.45
			TOTAL:	\$156.45
		MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,		
		2015-09-10		
		CUSTOMER SIGNATURE DATE		