

2014-07-11

DATE

HST #837181627

DATE 2014-07-11	TECHNICIAN Darren Mann		JOB/ORDER # 3543		REFERENCE TEXT Client reference
FIRST NAME Alicia		LAST NAME Francella	97		
BILLING ADDRESS COMPANY / BILLING NAME 1252 HORNBY STREET VANCOUVER, V6Z 0A3 BRITISH COLUMBIA, CANADA		4	SERVICE ADDRESS 1004 - 1252 HORNBY STREET BUZ#2115 CHRIS(TENANT): 604.780.3450 VANCOUVER, V6Z 0A3 BRITISH COLUMBIA, CANADA		
PHONE 604.781.1737				EMAIL alicia.francella@shaw.ca	

REASON FOR TODAY'S CALL:

kitchen tap - no water coming out

DESCRIPTION OF WORK PERFORMED:

July11---I removed faulty check valve from within faucet. This check valve diverts water from main spout to the side spray, without this piece the faucet now works but the side spray does not. I have emailed American Standard about having parts mailed out.

TECHNICIAN RECOMMENDATIONS:

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Labour	\$99.00	\$99.00
Q		SUBTOTAL:	\$99.00	
Gwe us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank Youl		LABOUR - 1 YEAR ON NEW UNITS, 30	DAYS ON REPAIR, VOID AFTER 30 DAYS IF UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	\$4.9
			TOTAL:	\$103.9
		e did. MADE THAT SERVICES LISTED ABOVE ARE SATISFAC MATERIALS LISTED HEREON ARE CORRECT. YALETC SETTLED, RUSSED DETERIORATION, OR LEAD PIPE	TORY COMPLETED AND THAT CHARGES AND WN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, , FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES G FIXTURES OR PIPING.	

CUSTOMER SIGNATURE