

Phone: 604.727.4484 yaletownplumbing.com



HST #837181627

UNIT PRICE PRICE

DATE 2015-11-12	TECHNICIAN		JOB/ORDER # 5520	REFERENCE TEXT
FIRST NAME Laura		LAST NAME Robertson		
BILLING ADDRESS GROUNDWORK ATHLET 10 - 736 GRANVILLE ST VANCOUVER, V6Z 1G3 BRITISH COLUMBIA, CA			SERVICE ADDRESS  10 - 736 GRANVILLE S VANCOUVER, V6Z 1G BRITISH COLUMBIA, 0	3
PHONE 604.685.7576			EMAIL gwareception@gmail.com	

## REASON FOR TODAY'S CALL:

-middle shower running in men's bathroom.

## **DESCRIPTION OF WORK PERFORMED:**

I replaced the cartridge and then noticed the integral shut off valves were deteriorating and flaking off. We located the main water shut off, repaired the integral stops and re-pressurized the system slowly. Tested and in good working order.

## TECHNICIAN RECOMMENDATIONS:

It was suggested that all of the integral stops be repaired as they are all probably starting to deteriorate at the same rate as the ones repaired. It would be best to have this done after hours so as to not disrupt the flow of business.

**DESCRIPTION** 

1	$\Pi_{\mathcal{A}}$	Replace Shower Cartridge - Delta		\$199.00
2		Repair Integral Stop	\$50.00	\$100.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			SUBTOTAL:	\$299.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$14.95
			TOTAL:	\$313.95

Thank You!

invoice and tell us how we did.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2015-11-12 CUSTOMER SIGNATURE DATE