



HST #837181627

DATE 2016-01-18	TECHNICIAN Darren Mann		JOB/ORDER # 5729		REFERENCE TEXT Client reference
FIRST NAME Alastair		LAST NAME Anderson			
BILLING ADDRESS COMPANY / BILLING NAME 618 - 22 E CORDOVA STREET VANCOUVER, V6A 4G8 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS  618 - 22 E CORDOVA STREET BUZZER: PHONE VANCOUVER, V6A 4G8 BRITISH COLUMBIA, CANADA	
PHONE 778.891.7684				EMAIL alastair.anderson@gmail.com	

## REASON FOR TODAY'S CALL:

Bath spout needs to be replaced. The diverter is gunked up so water is leaking out the spout when the shower is on. Also the toilet needs a new stopper.

## DESCRIPTION OF WORK PERFORMED:

I installed a new delta pull-down type diverter spout. I also tightened the packing nut on the WC shut off valve and replaced the flapper

QTY.	CODE	DESCRIPTION			PRICE
1		Replace Standard Tub Spout Diverter			\$159.00
1	2465350	214L HORNET UNIV FLAPPER RBR			\$10.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				SUBTOTAL:	\$169.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your			<u>LABOUR</u> - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$8.45
		s from your	WARRANTY ON CUSTOMER SUPPLIED MATERIALS.  FREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY		\$177.45

<u> Thank You!</u>

invoice and tell us how we did.

WARRANT FON COSTOMER SUPPLIED MATERIALS.	
INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKN MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT R SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUT RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING TERMS. NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, M. CHARGES. E. & O. E.	OTHAT CHARGES AND RESPONSIBLE FOR BROKEN, I'S AND ANY OTHER DAMAGES
	2016-01-18
CUSTOMER SIGNATURE	DATE