



HST #837181627

DATE 2016-02-03	TECHNICIAN Darren Mann		JOB/ORDER # 5820		REFERENCE TEXT Client reference
FIRST NAME Easyrent		LAST NAME Admin	97		
BILLING ADDRESS EASYRENT REAL ESTATE SERVICES LTD. 100 - 1290 HOMER ST VANCOUVER, V6B2Y5 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 504 - 555 JERVIS ST KEYS AT OFFICE VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.662.3279				EMAIL info@easyrent.ca	

REASON FOR TODAY'S CALL:

Toilet running.

DESCRIPTION OF WORK PERFORMED:

The toilet flapper was warped and the fillvalve was not fully shutting the water off when the tank was full. I replaced the fillvalve, flapper, and supply line. The wc shut off valve located on the wall behind the toilet was leaking from a loose packing nut, I tightened this nut and tested.

TECHNICIAN RECOMMENDATIONS:

The toilet is secure and is showing no signs that the wax seal has been compromised.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace Toilet FillValve, Flapper, Supply - Standard	\$169.00	\$169.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				\$169.00
	it our feedbac	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$8.45
www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did.			TOTAL:	\$177.45
		INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY		

<u> Thank You!</u>

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2016-02-03 CUSTOMER SIGNATURE DATE