



DATE 2016-02-04	TECHNICIAN Darren Mann	JOB/ORDER # 5823	REFERENCE TEXT Client reference
FIRST NAME Lynden		LAST NAME Wei	
BILLING ADDRESS DUNOWEN PROPERTIES 201 - 1288 ALBERNI STREET VANCOUVER, V6E 4N5 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 2902 - 1200 ALBERNI VANCOUVER, V6E 4N5 BRITISH COLUMBIA, CANADA	
PHONE 778.919.9810		EMAIL operations@dunowen.com	

REASON FOR TODAY'S CALL:
Master bathroom hot water knob won't shut fully *Supergrif

DESCRIPTION OF WORK PERFORMED:
 ---Feb4: Cartridges from Supergrif were the wrong size. The tenant said the master tub wasn't draining well but I tested it by filling the tub 6" and draining and it is draining very well. ---Feb15: I delivered and installed a new Delta Lahara lavatory faucet. The hot shut off valve under the lavatory sink was not fully shutting off the water so I installed a retro stop.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Supply & Install Delta Lav Faucet - Lahara 8"CC CP 3538 MPUDST	\$439.00	\$439.00
1		3/8" Retro-Stop	\$25.00	\$25.00

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$464.00
GST (5%):	\$23.20
TOTAL:	\$487.20

_____ 2016-02-04

 CUSTOMER SIGNATURE DATE