



2016-05-02

DATE

HST #837181627

DATE 2016-05-02	TECHNICIAN Darren Mann		JOB/ORDER # 6095		REFERENCE TEXT Client reference
FIRST NAME Joanne		LAST NAME Hagel			
BILLING ADDRESS COMPANY / BILLING NAME 212 - 2228 MARSTRAND AVE VANCOUVER, V6K4T1 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 212 - 2228 MARSTRAND AVE, BUZZER 024 MYRIAM: 604 816 5904 MY HUSBAND'S NUMBER: 604 314 4885 VANCOUVER, V6K4T1 BRITISH COLUMBIA, CANADA	
PHONE 778.985.8924				EMAIL Hagel@shaw.ca	

REASON FOR TODAY'S CALL:

-install customer supplied fillvalve

DESCRIPTION OF WORK PERFORMED:

---May2: The shut off valve for the toilet is not working, this valve will have to be repaired before the new fillvalve can be installed. The tenant did not know the location of the main shut off valves. ---May24: I repaired the toilet shut off valve by replacing the washer, stem, packing, packing nut, and handle, then installed the customer supplied fillvalve. Tested and in good working order.

QTY.	CODE		UNIT PRICE	PRICE	
1	7	Quoted Price		\$199.00	\$199.00
0	Gwe us Feedback warranty		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$199.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$9.95
			WARRANTY ON CUSTOMER SUPPLIED MATERIALS. INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY	TOTAL:	\$208.95
			MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES, E. & O. E.		

CUSTOMER SIGNATURE