



DATE 2016-06-08	TECHNICIAN Darren Mann	JOB/ORDER # 6215	REFERENCE TEXT Client reference
FIRST NAME Jae Shin		LAST NAME Kim	
BILLING ADDRESS COMPANY / BILLING NAME 3001 - 1200 WEST GEORGIA ST VANCOUVER, V6E 4R2 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 903 - 939 HOMER ST, BUZ#0135 TREVOR RUSH(TENANT): 778-877-1639 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 778.938.1896		EMAIL bobbykim7@hotmail.com	

REASON FOR TODAY'S CALL:

It seems that the water pump in the toilet may have a problem. The water is coming out of the top of the pump through a lever where water isn't supposed to flow through, it's supposed to flow through the bottom of the tank. The toilet still works, but I'm just wondering if this needs to be dealt before potential disaster"

DESCRIPTION OF WORK PERFORMED:

I replaced the FillValve & supply line and tested by flushing the toilet multiple times.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace toilet FillValve - standard	\$159.00	\$159.00

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$159.00
GST (5%):	\$7.95
TOTAL:	\$166.95

_____ 2016-06-08

 CUSTOMER SIGNATURE DATE