

HST #837181627

DATE 2016-08-11	TECHNICIAN Darren Mann		JOB/ORDER # 6393		REFERENCE TEXT Client reference
FIRST NAME Daryoush		LAST NAME Nikzad			
BILLING ADDRESS COMPANY / BILLING NAME 1336 - 1328 WEST PENDER ST VANCOUVER, V6E4T1 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1905 - 688 ABBOTT ST BUZ#3- CHELSIE(TENANT): 778.678.50 VANCOUVER, BRITISH COLUMBIA, CANADA	625
PHONE 604.537.3776 C				EMAIL d_nikzad@hotmail.com	

REASON FOR TODAY'S CALL:

Leaking tub faucet.

DESCRIPTION OF WORK PERFORMED:

The shower cartridge failed and was not shutting the water off, allowing hot water to continually flow through the tub spout. While removing the cartridge one of the integral shut off valves failed. I found the main water shut off valves in the storage closet, turned the water off, and repaired the integral shut off valves by replacing the washers, stems, packing, and packing nuts. I then installed the new Delta shower cartridge and tested.

QTY.	CODE		DESCRIPTION	UNIT PRICE	PRICE
1	1.	Replace Shower Cartridge - Delta		\$199.00	\$199.00
2		Repair Integral Stop		\$25.00	\$50.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback Fill in the required details from your		warranty:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$249.00
			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		\$12.45
		s from your			\$261.45

Thank You!

invoice and tell us how we did.

CUSTOMER SIGNATURE	DATE
	2016-08-11
CHARGES, E. & O. E.	. E. W. E. S. W. B. MOOK
MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RE SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MAT	S AND ANY OTHER DAMAGES
INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWN MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND T	