

HST #837181627

DATE 2016-08-31	TECHNICIAN Darren Mann		JOB/ORDER # 6454		REFERENCE TEXT Client reference	
FIRST NAME Yuri		LAST NAME Stratton				
BILLING ADDRESS COMPANY / BILLING NAME 1866 WEST 15TH AVE VANCOUVER , V6J2K9 BRITISH COLUMBIA, CANADA			2 - 303 ROSEL VANCO	CE ADDRESS 6 WEST 4TH AVE LYN(TENANT): 778.323. DUVER , H COLUMBIA, CANAD <i>I</i>		
PHONE 604.364.6862			EMAIL yuririab	adillo@hotmail.com		

REASON FOR TODAY'S CALL: running toilet

DESCRIPTION OF WORK PERFORMED:

The toilet flapper was warped, the FillValve was spraying out of the top, the overflow tube was cracked, and the handle was stripped. I removed the toilet tank, replaced the FillValve, flushvalve assembly, flapper, and handle. Then I re-installed the tank with a new tank to bowl gasket, tank bolts, and supply line. Tested and in good working order.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	//	Complete Toilet Tank Rebuild	\$229.00	\$229.00
0	SUBTOTAL:	\$229.00		
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$11.45
		s from your	TOTAL:	\$240.45
		Ve did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY CUMPILETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTI FOR PURITED PRETENDATION OF LEAD PURIS		

CUSTOMER SIGNATURE

2016-08-31