



DATE 2016-09-02	TECHNICIAN Darren Mann	JOB/ORDER # 6452	REFERENCE TEXT Client reference
FIRST NAME Lenny		LAST NAME Ford	
BILLING ADDRESS COMPANY / BILLING NAME 906 - 328 E 11TH AVE VANCOUVER, V5T 4W1 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 906 - 328 E 11TH AVE, BUZZER 5640 VANCOUVER, V5T 4W1 BRITISH COLUMBIA, CANADA	
PHONE 778.998.8853		EMAIL youcanreachlenny@gmail.com	

REASON FOR TODAY'S CALL:
 water pressure dropped off dramatically a few weeks ago and now next to no water coming out of the tap. took the head off to see if it was maybe the filter but seems to be a problem further down the line as the pressure was still low.

DESCRIPTION OF WORK PERFORMED:
 -I repaired the hot and cold shut off valves under the kitchen sink and flushed debris out of the faucet lines. Tested and in good working order.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Repair 1/2" x 3/8" Angle or Straight Stop	\$139.00	\$139.00
1		Repair 1/2" x 3/8" Angle or Straight Stop - ADD-ON	\$25.00	\$25.00
SUBTOTAL:			\$164.00	\$164.00
GST (5%):			\$8.20	\$8.20
TOTAL:			\$172.20	\$172.20

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2016-09-02

CUSTOMER SIGNATURE

DATE