

Phone: 604.727.4484 yaletownplumbing.com

2016-09-13

DATE

HST #837181627

DATE 2016-09-13	TECHNICIAN Darren Mann		JOB/ORDER # 6487		REFERENCE TEXT Client reference	
FIRST NAME EMILY		LAST NAME BURNS	97			
BILLING ADDRESS COMPANY / BILLING NAME 204 - 1295 RICHARDS ST VANCOUVER, V6B1B7 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 204 - 1295 RICHARDS STREE JP(TENANT): 778.709.1102 BUZZER: 018 VANCOUVER, V6B1B7 BRITISH COLUMBIA, CANADA		
PHONE 778.709.1102				EMAIL BURNSEMILYM@GMAIL.COM		

REASON FOR TODAY'S CALL:

-replace garburator(Badger5) -install customer supplied shower head

DESCRIPTION OF WORK PERFORMED:

-I replaced the garburator with a new Badger5 and tested by filling and draining the sink while running the garburator. -I installed the customer supplied shower head and tested.

TECHNICIAN RECOMMENDATIONS:

During testing of the shower head I noticed that the tub spout is leaking where it connects to the wall. The tenant mentioned that this spout was just recently installed by another plumbing company, I suggested contacting them and letting them know ASAP. *before installing a new spout we always use silicone to seal around the copper where it comes through tile to ensure that if the spout were to fail in the future the water will run down the front of the tile and into the tub. If this was not sealed then the water leaking from the spout could very be leaking behind the tile. In any case it should be rectified ASAP.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Supply & Install 1/2HP Badger5 Garburator	\$309.00	\$309.00
0		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$309.00
Gwe us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$15.45
			TOTAL:	\$324.45
		WE did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED PLETED DETERINDATION OF LEAD PIPES ENTITIES OF EAN OUTS AND ANY OTHER DAMAGES.		

CUSTOMER SIGNATURE