

Phone: 604.727.4484 yaletownplumbing.com



2016-10-04

DATE

HST #837181627

DATE 2016-10-04	TECHNICIAN Darren Mann		JOB/O 6567	RDER #	REFERENCE TEXT Client reference
FIRST NAME Nata		LAST NAME Belcham			
BILLING ADDRESS COMPANY / BILLING NAME 301 - 1157 NELSON ST VANCOUVER, V6E1J3 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 301 - 1157 NELSON STREET BUZZER: 301 DEVRA(MOM): 1.647.625.2508 VANCOUVER, V6E1J3 BRITISH COLUMBIA, CANADA	
PHONE 604.790.6421	-			EMAIL nata.belcham@gmail.com	

REASON FOR TODAY'S CALL:

-drain pipe under our kitchen sink seems to have a slow leak. -shower drain clogged. -lavatory sink draining slow.

DESCRIPTION OF WORK PERFORMED:

-I used the PowerSpin drain snake to clean hair from the shower drain. -I tried to clear the lavatory sink drain with the PowerSpin drain snake for an hour but it felt as though the snake was being guided up the vent rather than down the drain. -The kitchen sink basket strainer was installed incorrectly and the drainage was poorly measured. I re-installed the basket strainer properly and cut in a new Bow adaptor to align the drainage properly. Tested by filling and draining the sink multiple

TECHNICIAN RECOMMENDATIONS:

I suggest contacting the plumbing company that deals with the buildings main mechanical systems to have them take a look at the lavatory sink drain. It is possible

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Clean drain using PowerSpin / Tub/Shower	\$149.00	\$149.00
1		Bow Adaptor	\$10.00	\$10.00
<i>Q</i>	Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			\$159.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank Youl		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.9
			TOTAL:	\$166.9
		WE did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED BUSTED DETERIORATION OR LEAD PIPES FIXTURES OF AN OUTS AND ANY OTHER DAMAGE	3	

CUSTOMER SIGNATURE