

Phone: 604.727.4484 yaletownplumbing.com

(B) @SimplyPlumbing f YaletownPlumbing

HST #837181627

GST (5%):

TOTAL:

\$8.20

\$172.20

DATE 2016-10-28	TECHNICIAN Darren Mann		JOB/O 6662	RDER #	REFERENCE TEXT
FIRST NAME Corry		LAST NAME Buchanan	7		
BILLING ADDRESS 110 - 1020 MAINLAND ST VANCOUVER, V6B 2T4 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 3250 WEST 2ND AVE CHENG: 604.375.3722 VANCOUVER,	
PHONE 778.980.9900				BRITISH COLUMBIA, CANADA EMAIL corry@rentitfurnished.com	

REASON FOR TODAY'S CALL: Kitchen faucet has low water pressure.

## DESCRIPTION OF WORK PERFORMED:

-The Hot shut off valve under the kitchen sink was worn out and blocking the flow of water to the faucet. I repaired this valve, as well as the Cold valve, by replacing the washers, stems, packing, packing nuts, and handles. Tested and the pressure is back to normal. -While onsite the tenant mentioned that his lavatory sink was slow to drain. I was able to get it flowing freely by removing sludge from the top of the drain.

	QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
	1	1.	Repair 1/2" x 3/8" Angle or Straight Stop	\$139.00	\$139.00
	1		Repair 1/2" x 3/8" Angle or Straight Stop - ADD-ON	\$25.00	\$25.00
	0	. 6		SUBTOTAL:	\$164.00

## Gwe us Geedback

Please visit our feedback page at: www.yaletownplumbing.com/feedback [1]

Fill in the required details from your invoice and tell us how we did.

<u> Thank You!</u>

ARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY							
	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.							
MADE THAT MATERIALS I SETTLED, RU RESULTING I	THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLET JISTED HEREON ARE CORRECT. YALETOWN PLUMBING I JISTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLR FROM CLEANING OR REPAIRING EXISTING FIXTURES OR CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LAB . & O. E.	TED AND THAT CHARGES AND S NOT RESPONSIBLE FOR BROKEN, EAN OUTS AND ANY OTHER DAMAGES PIPING.						
		2016-10-28						
	CUSTOMER SIGNATURE	DATE						