

Phone: 604.727.4484 yaletownplumbing.com

(E) @SimplyPlumbing f YaletownPlumbing

HST #837181627

| DATE 2016-11-02 | TECHNICIAN Darren Mann | | JOB/ORDER # 6653 | | REFERENCE TEXT Client reference |
|--|---------------------------|------------------------|---------------------|--|------------------------------------|
| FIRST NAME Werner | | LAST NAME Antweiler | 7 | | |
| BILLING ADDRESS COMPANY / BILLING NAME 6288 LOGAN LANE VANCOUVER, V6T 2K9 BRITISH COLUMBIA, CANADA | | | 4 | SERVICE ADDRESS 6288 LOGAN LANE VANCOUVER, V6T 2K9 BRITISH COLUMBIA, CANADA | |
| PHONE 604-222-9722 | | | | EMAIL werner.antweiler@ubc.ca | |

REASON FOR TODAY'S CALL:

Both the hot-water and cold-water taps on bathtub stopped working; there is no water flow whatsoever. The bathtub was not used for about half a year. Conveniently for servicing, the bathtub plumbing is accessible through a removable access panel on the far side of the wall facing the bathtub. A problem with the same taps (sputtering) was fixed a few years ago.

DESCRIPTION OF WORK PERFORMED:

-The issue was again caused by the diverter cartridge located just below the junction of the Hot & Cold water lines. I removed the brass cap, tapped the diverter up to the open position, and used a small spacer I cut from a piece of 1/2" Wirsbo pipe to hold it u. I re-installed the brass cap and tested, water is now flowing freely with no sign of leaking below.

| QTY . | CODE | | UNIT PRICE | PRICE | |
|---|--|-----------|--|----------|----------|
| 1 | 10 | Labour | | \$109.00 | \$109.00 |
| Give us Feedback Please visit our feedback page at: <u>www.yaletownplumbing.com/feedback</u> [1] Fill in the required details from your | WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY | SUBTOTAL: | \$109.00 | | |
| | LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO | GST (5%): | \$5.45 | | |
| | WARRANTY ON CUSTOMER SUPPLIED MATERIALS. INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY | TOTAL: | \$114.45 | | |
| <u>Thank You!</u> | | <u>u!</u> | MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. <u>TERMS</u> : NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E. | | |