

(SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2016-11-23	TECHNICIAN Darren Mann		JOB/ORDER # 6720		REFERENCE TEXT Client reference	
FIRST NAME Frank		LAST NAME Gelson	7			
BILLING ADDRESS COMPANY / BILLING NAME 1305 - 1088 QUEBEC ST VANCOUVER, V6A 4H2 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1305 - 1088 QUEBEC STREET BUZZER: 079 VANCOUVER, V6A 4H2 BRITISH COLUMBIA, CANADA		
PHONE 604.605.3205				EMAIL frank1937@mac.com		

REASON FOR TODAY'S CALL: Small toilet leak. Seal?

DESCRIPTION OF WORK PERFORMED:

The left tank bolt was broken, allowing water to trickle out onto the floor under the toilet. I removed the tank and re-installed with a new supply line, tank bolts, and tank to bowl gasket. Tested and no leaks present.

QTY.	CODE			DESCRIPTION	UNIT PRICE	PRICE	
1	/	Replace Standard Toilet Tank Bolts & Gasket				\$139.00	\$139.00
Gwe us Feedback Please visit our feedback page at:	WARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS. THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS, ACKNOWLEDGEMENT IS HEREBY		SUBTOTAL:	\$139.00		
				GST (5%):	\$6.95		
www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!				TOTAL:	\$145.95		
		MATERIALS L SETTLED, RU RESULTING F	SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AN ISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT STED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN O ROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPIN CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, & O. E.				
				CUSTOMER SIGNATURE	DATE		