

Phone: 604.727.4484 yaletownplumbing.com

🕒 @SimplyPlumbing 🛛 🚹 YaletownPlumbing

HST #837181627

DATE 2017-02-09	TECHNICIAN Darren Mann		JOB/O 7001	RDER #	REFERENCE TEXT
FIRST NAME Mike		LAST NAME Truscott	7		
BILLING ADDRESS		10	7,	SERVICE ADDRESS	
2107 - 989 RICHARDS ST VANCOUVER, V6B 6R6 BRITISH COLUMBIA, CANADA				2107 - 989 RICHARDS ST, BUZ MARK: 604.551.7247 VANCOUVER, V6B 6R6 BRITISH COLUMBIA, CANADA	
PHONE 778-231-4174				EMAIL michaeljtruscott@gmail.com	

REASON FOR TODAY'S CALL: Leak under kitchen sink

DESCRIPTION OF WORK PERFORMED:

The Hot shut off valve under he kitchen sink(supplying faucet) was leaking. I tried to tighten the packing nut but the leaking persisted. I repaired the shut off valve by replacing the washer, stem, packing, packing nut, and handle. Tested and in good working order.

TECHNICIAN RECOMMENDATIONS:

I noticed some staining on the Cold valve but no sign of leaking. I believe this staining is likely caused by condensation which is no cause for alarm but I asked Mark to keep an eye on it over the next few days to make that no moisture is detected.

QTY. CODE	DESCRIPTION	UNIT PRICE	PRICE
1	Repair 1/2" x 3/8" Angle or Straight Stop	\$139.00	\$139.00
Que e c	WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$139.00
Give us S Please visit our feedb	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$6.95
www.yaletownplumbin Fill in the required det		TOTAL:	\$145.95
invoice and tell us how	MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,		