



2017-04-04

DATE

HST #837181627

DATE 2017-04-04	TECHNICIAN Darren Mann		JOB/O 7175	RDER #	REFERENCE TEXT Client reference
FIRST NAME Ericka		LAST NAME Dragan	97		
BILLING ADDRESS COMPANY / BILLING NAME 905 BEACH AVE VANCOUVER, V6Z 1E1 BRITISH COLUMBIA, CANADA			14	SERVICE ADDRESS 905 BEACH AVE VANCOUVER, V6Z 1E1 BRITISH COLUMBIA, CANADA	
PHONE 604.837.6952				EMAIL max@rektek.com	

REASON FOR TODAY'S CALL:

issues with water temp fluctuating in Aquabrass thermostatic shower.

DESCRIPTION OF WORK PERFORMED:

---Apr4: I made a trip to the unit and found that the integral shut off valves were not functioning. I contacted Jeff from Cantu and ordered parts ---Apr18: I replaced the integral Hot & Cold check valves & stop screws(11678) and Thermostatic cartridge(11042). Tested and in good working order.

TECHNICIAN RECOMMENDATIONS:

Ericka mentioned that they frequently run out of hot water. I suggested calling Montalbano Plumbing(604.444.0222) and having them in to inspect the Hot Water

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
3.5		Labour	\$109.00	\$381.50
<i>Q</i>		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$381.50
Gwe us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank Youl		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$19.08
			TOTAL:	\$400.58
		MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN SETTLED RUSTED DETERIORATION OR LEAD PIPES FIXTURES CLEAN QUITS AND ANY OTHER DAMAGE.		

CUSTOMER SIGNATURE