

HST #837181627

DATE 2017-04-24	TECHNICIAN Darren Mann		JOB/ORDER # 7227		REFERENCE TEXT Client reference				
FIRST NAME Samantha		LAST NAME Strebchuk	97						
BILLING ADDRESS COMPANY / BILLING NAME 1006 - 1238 RICHARDS ST VANCOUVER , V6B6M6 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1006 - 1238 RICHARDS ST ROSSI(PARTNER): 778-996-10 VANCOUVER , V6B6M6 BRITISH COLUMBIA, CANADA					
PHONE 604-345-7759				EMAIL samanthastrebchuk@gmail.com	n				

REASON FOR TODAY'S CALL:

The faucet in picture shown will not turn off when main cold water supply is on. There no hot water coming out of the faucet what so ever.

DESCRIPTION OF WORK PERFORMED:

The cartridge was stripped internally. The Integral stops were not fully shutting the water off, I repaired the Hot & Cold Integral stops by replacing the washers, stems, packing, and packing nuts. I then flushed out the valve and installed the new cartridge(Tamp ii). Tested and in good working order.

QTY.	CODE	DESCRIPTION		UNIT PRICE	PRICE
2		Repair Integral Stop			\$50.00
1	11	Replace Shower Cartridge - Temp II		\$209.00	\$209.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			SUBTOTAL:	\$259.00	
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		\$12.95
					\$271.95

Thank You!

invoice and tell us how we did.

CUSTOMER SIGNATURE	DATE
	2017-04-24
CHARGES. E. & O. E.	
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATE	RIALS AND TRUCK
SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS A RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING	
MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND TH MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RES	
INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOW	VLEDGEMENT IS HEREBY