

HST #837181627

DATE 2017-05-03	TECHNICIAN Darren Mann		JOB/ORDER # 7253		REFERENCE TEXT Client reference
FIRST NAME Laura		LAST NAME Robertson			
BILLING ADDRESS COMPANY / BILLING NAME 1205 - 1001 HOMER ST VANCOUVER, V6B 1M9 BRITISH COLUMBIA, CANADA		9	4	SERVICE ADDRESS  1205 - 1001 HOMER ST. BUZZER: 2316 VANCOUVER, V6B 1M9 BRITISH COLUMBIA, CANADA	
PHONE 778.886.7152				EMAIL lauraroserobertson@gmail.com	

## REASON FOR TODAY'S CALL:

Thank You!

chronic leak at the connection between water intake and the tank.

## DESCRIPTION OF WORK PERFORMED:

The leak was coming from the bottom of the fillvalve. I replaced the FillValve and supply and tested.

QTY.	CODE		UNIT PRICE	PRICE	
1	//	Replace toilet FillValve - standard	\$159.00	\$159.00	
e	, (I	warranty: PARTS - SL	<u>PARTS</u> - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$159.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your invoice and tell us how we did.		c page at:	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		\$7.95
		com/reedback [1]			\$166.95
		Ve did. MADE THAT SERVICES LIST MATERIALS LISTED HEREO SETTLED, RUSTED, DETER	INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.		

CUSTOMER SIGNATURE

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK

2017-05-03 DATE