

Phone: 604.727.4484 yaletownplumbing.com

2017-05-25

DATE

HST #837181627

DATE 2017-05-25	TECHNICIAN Darren Mann		JOB/ORDER # 7322	REFERENCE TEXT Client reference
FIRST NAME Asad		LAST NAME Mohiuddin		
BILLING ADDRESS COMPANY / BILLING NAME 311 - 939 HOMER ST VANCOUVER, V6B2W6 BRITISH COLUMBIA, CANADA			SERVICE ADDRESS  311 - 939 HOMER ST BUZ#0316 VANCOUVER, V6B2W BRITISH COLUMBIA, 0	
PHONE 1.425.647.3245		EMAIL asad.mohiuddin@gmai	EMAIL asad.mohiuddin@gmail.com	

## REASON FOR TODAY'S CALL:

The drainage of the toilet WC is a little slow and needs to be plunged a few times. The water does drain after a couple of plunges and after pouring water into the

## DESCRIPTION OF WORK PERFORMED:

-I used the 6' toilet auger to clear the toilet blockage. Tested by flushing large rolled up balls of paper towel. Nothing was pulled out of the toilet, whatever caused the blockage was pushed through and flushed away. -I adjusted the flapper float to allow for more water per flush and mitigate the chances of further clogging. -The shut off valve was leaking from the stem. I tightened the packing nut which was loose and this stopped the leak. I have suggested keeping a container under the valve for one week to ensure the leak has fully subsided.

QTY.	CODE	DESCRIPTION		PRICE
1		Clear toilet blockage using 6' toilet auger		\$139.00
Give us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			SUBTOTAL:	\$139.00
Please visit our feedback page at:  www.yaletownplumbing.com/feedback [1]  Fill in the required details from your invoice and tell us how we did.  Thank You!		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$6.95
			TOTAL:	\$145.95
		WE did.  MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND  MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,  SETTLED PLISTED DETERIORATION OF LEAD PIPES FLYTURES OF EARLOUTS AND ANY OTHER DAMAGES.		

CUSTOMER SIGNATURE

CHARGES. E. & O. E.