

Phone: 604.727.4484 yaletownplumbing.com

HST #837181627

DATE 2017-07-24	TECHNICIAN Darren Mann		JOB/ORDER # 7538	REFERENCE TEXT Client reference		
FIRST NAME Geraldine		LAST NAME Pratt				
BILLING ADDRESS COMPANY / BILLING NAME 2633 WEST 11TH AVENUE VANCOUVER, V6K 2L7 BRITISH COLUMBIA, CANADA			2633 WEST 11TH AV VANCOUVER, V6K 2	SERVICE ADDRESS 2633 WEST 11TH AVENUE VANCOUVER, V6K 2L7 BRITISH COLUMBIA, CANADA		
PHONE 604.833.9773			EMAIL gpratt@geog.ubc.ca			

REASON FOR TODAY'S CALL:

Our toilet running. Replaced flap but issue not resolved. Or maybe installed wrong!

DESCRIPTION OF WORK PERFORMED:

The flapper wasn't seating correctly and the fillvalve was fully shutting off when the tank was full. I replaced the fillvalve, flapper, and supply line. Tested and in good working order.

TECHNICIAN RECOMMENDATIONS:

*The tank lever is not fully secure to the tank. I tried to secure it but the set screws are rusted and won't budge. If this is an issue a new lever will have to be ordered from Duravit.

QTY.	CODE		DESCRIPTION	UNIT PRICE	PRICE
1		Replace Toilet FillValve,	Flapper, Supply - Standard	\$169.00	\$169.00
WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				SUBTOTAL:	\$169.00
Gwe us Feedback Please visit our feedback page at:			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$8.45
www.yaletownplumbing.com/feedback [1] Fill in the required details from your		s from your	WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		\$177.45

Thank You!

invoice and tell us how we did.

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2017-07-24 CUSTOMER SIGNATURE DATE