

Phone: 604.727.4484 yaletownplumbing.com

(E) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2017-08-15	TECHNICIAN Darren Mann		JOB/O 7615	RDER #	REFERENCE TEXT Client reference
FIRST NAME Robin		LAST NAME Soni	7		
BILLING ADDRESS COMPANY / BILLING NAME 1111 WEST 73RD AVE VANCOUVER, V6P3E6 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 604 - 1255 SEYMOUR ST SOPHIE: 1.416.919.9441 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.376.3240				EMAIL robin.soni@boydautobody.com	

REASON FOR TODAY'S CALL:

We have a toilet that won't stop running. The water won't shut off using the valve on the wall behind the toilet, and the mechanism inside the toilet is also broken. No other problems with our second toilet or taps noted, but we'd like a quick check to make sure everything else is working correctly as well.

## DESCRIPTION OF WORK PERFORMED:

The main cold water shut off valve was not accessible, it had been dry walled over. I cut an access in the drywall to access this main valve and repaired the WC shut off valve(connected to toilet) by replacing the washer, stem, packing nut, and handle. I then replaced the toilet FillValve, flapper, and supply line. Tested and in good working order. Tenant reports that all other fixtures are functioning normally.

<b>QTY.</b>	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	1.	Replace Toilet FillValve, Flapper, Supply - Standard	\$169.00	\$169.00
1		Repair 1/2" x 3/8" Angle or Straight Stop - ADD-ON	\$25.00	\$25.00
			SURTOTAL	¢104.00

Gwe us Feedback	WARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			
Please visit our feedback page at:		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID A MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NO		GST (5%):	\$9.70
www.yaletownplumbing.com/feedback [1]		WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		TOTAL:	\$203.70
Fill in the required details from your invoice and tell us how we did.		AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNO SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND T			
<u> Thank You!</u>	SETTLED, R RESULTING	LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RE USTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. I CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MAT E. & O. E.	S AND ANY OTHER DAMAGES		
	J		2017-08-15		
		CUSTOMER SIGNATURE	DATE		