



2017-09-15

HST #837181627

DATE 2017-09-15	TECHNICIAN Darren Mann		JOB/ORDER # 7705		REFERENCE TEXT Client reference
FIRST NAME Colin		LAST NAME Doig			
BILLING ADDRESS RE/MAX CREST REALTY WESTSIDE 1428 WEST 7TH AVE VANCOUVER, V6H1C1 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 120 - 3133 RIVERWALK AVE MURILO: MURILOLIMA2504@GMAIL.COM 778-882-2431 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.417.9003	-			EMAIL colin@colindoig.com	

REASON FOR TODAY'S CALL:

Toilet leaking

DESCRIPTION OF WORK PERFORMED:

The leak was coming from the bottom of the fillvalve. I removed the tank, replaced the fillvalve, and reinstalled the tank with a new braided supply line. Tested and no leaks present.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	//,	Replace toilet FillValve - standard	\$159.00	\$159.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				\$159.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank Youl		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.95
			TOTAL:	\$166.95
		We did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLE DESCRIPTION OF THE PROPERTY OF THE PROPE		