



DATE 2017-09-21	TECHNICIAN Darren Mann	JOB/ORDER # 7740	REFERENCE TEXT Client reference
FIRST NAME Julie		LAST NAME Ruehle	
BILLING ADDRESS COMPANY / BILLING NAME 3803 - 1077 WEST CORDOVA ST VANCOUVER, V6C2C6 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 3803 - 1077 WEST CORDOVA ST, BUZZER N/A CONCIERGE WILL GRANT ACCÈS TO FLOOR. VANCOUVER, V6C2C6 BRITISH COLUMBIA, CANADA	
PHONE 1.858.692.5024		EMAIL julie_bahadori@yahoo.com	

REASON FOR TODAY'S CALL:
Toilet running(in wall tank system).

DESCRIPTION OF WORK PERFORMED:
It seemed as though the flushvalve assembly was stuck in the open position and one of the pneumatic button hoses popped out. I removed the flushvalve assembly, cleaned it out, and reinstalled. I reinstalled the pneumatic hoses, tested and the toilet is functioning normally.

TECHNICIAN RECOMMENDATIONS:
*The toilet is a Caroma Water Wafer. If parts are needed in the future the number to call is 1.877.378.6591


QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Labour	\$109.00	\$109.00
			SUBTOTAL:	\$109.00
			GST (5%):	\$5.45
			TOTAL:	\$114.45

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.



 CUSTOMER SIGNATURE

2017-09-21

 DATE