



HST #837181627

DATE 2017-11-08	TECHNICIAN Darren Mann		JOB/ORDER # 7892	REFERENCE TEXT Client reference						
FIRST NAME Darlyne		LAST NAME Sturrock								
BILLING ADDRESS COMPANY / BILLING NAME 2625 POINT GREY RD VANCOUVER, V6K1A4 BRITISH COLUMBIA, CANADA			2625 POINT GREY	SERVICE ADDRESS  2625 POINT GREY ROAD VANCOUVER, V6K1A4 BRITISH COLUMBIA, CANADA						
PHONE 604.202.6953			EMAIL darlyne@darlyne.c	EMAIL darlyne@darlyne.ca						

## REASON FOR TODAY'S CALL:

toilet makes a 'whooshing' sound several times per hour either coming from toilet or wall??

## **DESCRIPTION OF WORK PERFORMED:**

The flushvalve gasket was warped, allowing water to continuously trickle from the tank through the bowl. I replaced the flushvalve gasket and tested.

QTY.	CODE	DESCRIPTION			UNIT PRICE	PRICE
1	<b>Y</b>	Replace FlushValve Gasket - Geberit In-Wall			\$159.00	\$159.00
		VARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$159.00	
			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO		\$7.95	
		WARRANTY ON CUSTOMER SUPPLIED MATERIALS.		TOTAL:	\$166.95	
			ITEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY IADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND			

<u> Thank You!</u>

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.

TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES, E. & O. E.

2017-11-08

CUSTOMER SIGNATURE

DATE