

Phone: 604.727.4484 yaletownplumbing.com

(a) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2017-11-23	TECHNICIAN Darren Mann		JOB/OI 7927	RDER #	REFERENCE TEXT Client reference
FIRST NAME Chase		LAST NAME Melnychyn	7		
BILLING ADDRESS COMPANY / BILLING NAME 1305 - 1055 HOMER ST VANCOUVER, V6B1G3 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1305 - 1055 HOMER STREET BUZZER: 1416 VANCOUVER, V6B1G3 BRITISH COLUMBIA, CANADA	
PHONE 604-379-9374				EMAIL chase.melnychyn@gmail.com	

REASON FOR TODAY'S CALL:

1) Guest bathroom sink faucet continues to run despite being turned off. Started with drips and progressed to a steady stream over 48 hours. 2) Master bathroom sink. Stopper has come detached from mechanism which allows stopper to go up and down. No sure if mechanism has broke, or has merely come detached.

DESCRIPTION OF WORK PERFORMED:

?Guest Bathroom: I replaced the faulty cartridge within the lavatory faucet. ?Master Bathroom: I reattached the lavatory drain stamper to the lift rod.

QTY.	CODE			DESCRIPTION	UNIT PRICE	PRICE
1	/	Replace Lav Faucet Single Lever Cartridge - Standard				\$159.00
Give us Feedback Please visit our feedback page at: <u>www.yaletownplumbing.com/feedback</u> [1] Fill in the required details from your		WARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$159.00	
			LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$7.95	
		INTEREST AT	WARRANTY ON CUSTOMER SUPPLIED MATERIALS. THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY	TOTAL:	\$166.95	
	I tell us how v		MATERIALS L SETTLED, RU RESULTING F	SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND LISTED HEREON ARE CORRECT. VALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, ISTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES ROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK & 0. E.		