

2017-11-24

DATE

HST #837181627

DATE 2017-11-24	TECHNICIAN Darren Mann		JOB/ORDER # 7934		REFERENCE TEXT Client reference
FIRST NAME Melanie		LAST NAME Samuels	77		
BILLING ADDRESS COMPANY / BILLING NAME 2005 WEST 16TH AVE VANCOUVER, V6J2M6 BRITISH COLUMBIA, CANADA	A		2 V	ERVICE ADDRESS 005 WEST 16TH AVE ANCOUVER, V6J2M6 BRITISH COLUMBIA, CANADA	N
PHONE 604.812.9191				MAIL nsamuels@singleton.com	

REASON FOR TODAY'S CALL:

When the boys bathroom toilet upstairs flushes it leaks profusely from the base

DESCRIPTION OF WORK PERFORMED:

The leak was coming from between the tank and the bowl. I removed the tank, and reinstalled with a new tank to bowl gasket, tank bolts, and supply line. Tested and

no other leak	ks detected.				, 117	
QTY.	CODE	DESCRIPTION				PRICE
1	//	Replace Toilet Tank to Bowl Gasket				\$189.00
Rung	- G	eedlack w	ARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$189.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!		k page at:		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$9.45
		s from your	INTEREST AT	WARRANTY ON CUSTOMER SUPPLIED MATERIALS. THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY	TOTAL:	\$198.45
		we did.	MADE THAT S MATERIALS I SETTLED, RU RESULTING I	SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, JISTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK		

CUSTOMER SIGNATURE