



2017-12-01

DATE

HST #837181627

DATE 2017-12-01	TECHNICIAN Darren Mann		JOB/O 7973	RDER #	REFERENCE TEXT Client reference
FIRST NAME Clive		LAST NAME			
BILLING ADDRESS COMPANY / BILLING NAME 2203 - 583 BEACH CRESCENT VANCOUVER, V6Z3E6 BRITISH COLUMBIA, CANADA		9	4	SERVICE ADDRESS 2203 - 583 BEACH CRESCENT VANCOUVER, V6Z3E6 BRITISH COLUMBIA, CANADA	
PHONE 778.223.9122				EMAIL mwpluser@hotmail.com	

REASON FOR TODAY'S CALL:

Master Bathroom: ?toilet water not refilling?

DESCRIPTION OF WORK PERFORMED:

The fillvalve was malfunctioning, not refilling the tank on some flushes, and the flapper was starting to warp. I replaced the fillvalve, flapper, and supply line. Tested

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace Toilet FillValve, Flapper, Supply - Standard	\$169.00	\$169.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY				\$169.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!		k page at: LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$8.45
			TOTAL:	\$177.45
		WE did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES		

CUSTOMER SIGNATURE