



HST #837181627

DATE 2017-12-22	TECHNICIAN Darren Mann		JOB/ORDER # 8018		REFERENCE TEXT Client reference
FIRST NAME Juanita		LAST NAME Lohmeyer			
BILLING ADDRESS COMPANY / BILLING NAME 2209 - 1010 RICHARDS ST VANCOUVER, V6B1G2 BRITISH COLUMBIA, CANADA		4	SERVICE ADDRESS 2209 - 1010 RICHARDS ST, BUZ#3320 TRISTAN MELTON(TENANT): 778.231.6358 JENN: 604.379.3789 VANCOUVER, V6B1G2 BRITISH COLUMBIA, CANADA		
PHONE 604.317.0700				EMAIL juanitalohmeyer@gmail.com	

REASON FOR TODAY'S CALL:

The sink in the kitchen is dripping. Please call the landlord Juanita Lohmeyer at 604.317.0700 to confirm before any work is done.

DESCRIPTION OF WORK PERFORMED:

The leak was coming from the casing of the water filter(right side). I also noticed that the filtered water tap was installed too far away from the sink. If the cartridge within this tap was ever to fail it would leak onto the counter instead of in the sink. I disconnected the water filtration system for now. When Juanita is back from vacation she can decide how she would like to proceed.

QTY.	CODE		DESCRIPTION	UNIT PRICE	PRICE
1	<i>1</i> .	Labour		\$109.00	\$109.00
1		20? Braided Lavatory Ex	tension	\$10.00	\$10.00
Q.,,,,	(1	eedback	ANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$119.00
	t our feedbac		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$5.95
	ownplumbing. equired detail	com/feedback [1] s from your	WARRANTY ON CUSTOMER SUPPLIED MATERIALS.	TOTAL:	\$124.95

Thank You!

invoice and tell us how we did.

MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK

	2017-12-22
CUSTOMER SIGNATURE	DATE