



DATE 2018-01-04	TECHNICIAN Darren Mann	JOB/ORDER # 8068	REFERENCE TEXT Client reference
FIRST NAME Dunowen Properties		LAST NAME Admin	
BILLING ADDRESS DUNOWEN PROPERTIES 201 - 1288 ALBERNI STREET VANCOUVER, V6E 4N5 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 1126 - 933 HORNBY ST VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.736.1900		EMAIL operations@dunowen.com	

REASON FOR TODAY'S CALL:  
Leak coming from toilet supply or fillvalve

DESCRIPTION OF WORK PERFORMED:  
The water supply to the toilet was turned off and the area dry. When I turned the water supply to the toilet back on I couldn't see any leaking but I did notice that the nut securing the fillvalve in place was cross threaded. I replaced the FillValve and supply line and tested.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace toilet FillValve - standard	\$159.00	\$159.00

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$159.00
GST (5%):	\$7.95
TOTAL:	\$166.95

\_\_\_\_\_ 2018-01-04  
 CUSTOMER SIGNATURE DATE