

Phone: 604.727.4484 yaletownplumbing.com

(E) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2018-01-12	TECHNICIAN Darren Mann		JOB/O 8056	RDER #	REFERENCE TEXT Client reference
FIRST NAME Chris		LAST NAME Cunningham	7		
BILLING ADDRESS COMPANY / BILLING NAME 404 - 1205 HOWE ST. VANCOUVER, V6Z0B2 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 404 - 1205 HOWE ST. BUZZER: 1515 VANCOUVER, V6Z0B2 BRITISH COLUMBIA, CANADA	
PHONE 778.874.4807				EMAIL chris.cunningham@ualberta.net	

REASON FOR TODAY'S CALL:

The toilet continues to run after flushing occasionally. We have to take the lid of the tank off and play with the valve to have the tank fill up... not every time but enough that we want it fixed.

DESCRIPTION OF WORK PERFORMED:

I replaced the mechanical portion of the FillValve and during testing noticed there was a small amount of water seeping out of the tank bolts. I removed the tank, installed a new tank to bowl gasket and reinstalled with a new braided supply line. I also replaced the flushvalve gasket as the original one was starting to bubble.

QTY .	CODE	DESCRIPTION		PRICE
1	1.	Replace FillValve, Flushvalve Gasket, Tank to Bowl Gasket, Supply Line	\$199.00	\$199.00
0		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$199.00
Give us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your	LABOUR - 1 YEAR ON NEW LINITS 30 DAYS ON REPAIR VOID AFTER 30 DAYS		\$9.95	
	com/feedback [1] WARRANTY ON CUSTOMER SUPPLIED MATERIALS.	TOTAL:	\$208.95	
That	<u>rk Yoi</u>		HER DAMAGES	