

2018-01-16

HST #837181627

DATE 2018-01-16	TECHNICIAN Darren Mann		JOB/ORDER # 8099	REFERENCE TEXT Client reference
FIRST NAME Natalie		LAST NAME Anderson		·
BILLING ADDRESS COMPANY / BILLING NAME 306 - 1345 WEST 4TH AVE VANCOUVER, V6Z3H8 BRITISH COLUMBIA, CANADA		2	SERVICE ADDRESS 306 - 1345 WEST 4TH AVE, BUZZER 46 LEIGH: 778-999-5107 VANCOUVER, V6Z3H8 BRITISH COLUMBIA, CANADA	
PHONE 778.772.8583 (Nat)	/		EMAIL nat3477@gmail.com	7/

REASON FOR TODAY'S CALL:

Guest Bathroom: Inspect toilet flapper.

DESCRIPTION OF WORK PERFORMED:

The fillvalve was not fully shutting off on some flushes, causing a faint hissing noise. I replaced the fillvalve & supply line and tested. The flapper seemed to be in good condition but it was reported that on occasion it doesn?t stay afloat when the tank lever is pressed. I found that if the lever was pushed super quick it may not activate the flapper but if it is pressed all the way it will activate the flapper every time.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1	// .	Replace toilet FillValve - standard	\$159.00	\$159.00
Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your invoice and tell us how we did. Thank You!		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$159.00
		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$7.95
			TOTAL:	\$166.95
		WE did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKE SETTLED RUSTED DETERIORATION OR LEAD PIPES FIXTURES CLEAN QUITS AND ANY OTHER DAM.	EN,	

CUSTOMER SIGNATURE